



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: Heidi Zaentz
 Monmouth Day Care Center
 9 Drs. James Parker Boulevard
 Red Bank, NJ 077010000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1423	9 Drs James Parker Boulevard - Red B	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**The parameters tested on this report PASSED NJ
 Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: Heidi Zaentz
 Monmouth Day Care Center
 9 Drs. James Parker Boulevard
 Red Bank, NJ 077010000

Laboratory Results

Sample Number	Sample Location	Collected By	Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1423	9 Drs James Parker Boulevard - Red B	Richard, Hand	0522-1423	5/14/2022 11:39:00 AM Kitchen Hand Wash Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-1			0522-1423-1	5/14/2022 11:39:00 AM Kitchen Hand Wash Sink	5/20/2022 8:25:00 AM	Copper	0.0990 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-10			0522-1423-10	5/14/2022 12:00:00 PM Room 2 Left Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-10			0522-1423-10	5/14/2022 12:00:00 PM Room 2 Left Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-11			0522-1423-11	5/14/2022 12:02:00 PM Room 2 Right Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-11			0522-1423-11	5/14/2022 12:02:00 PM Room 2 Right Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-12			0522-1423-12	5/14/2022 12:04:00 PM Room 1 Nursery Left Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	2.21 ug/l	15 ug/L	Std Method 3113B
0522-1423-12			0522-1423-12	5/14/2022 12:04:00 PM Room 1 Nursery Left Sink	5/20/2022 8:25:00 AM	Copper	0.0650 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-13			0522-1423-13	5/14/2022 12:05:00 PM Room 1 Nursery Right Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	3.35 ug/l	15 ug/L	Std Method 3113B
0522-1423-13			0522-1423-13	5/14/2022 12:05:00 PM Room 1 Nursery Right Sink	5/20/2022 8:25:00 AM	Copper	0.0590 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-2			0522-1423-2	5/14/2022 11:42:00 AM Kitchen Triple Sink Right	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-2			0522-1423-2	5/14/2022 11:42:00 AM Kitchen Triple Sink Right	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-3			0522-1423-3	5/14/2022 11:47:00 AM Room 6 Left Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-3			0522-1423-3	5/14/2022 11:47:00 AM Room 6 Left Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-4			0522-1423-4	5/14/2022 11:48:00 AM Room 6 Right Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Heidi Zaentz
Monmouth Day Care Center
9 Drs. James Parker Boulevard
Red Bank, NJ 077010000

Laboratory Results

Sample Number	Sample Location	Collected By
0522-1423	9 Drs James Parker Boulevard - Red B	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0522-1423-4	5/14/2022 11:48:00 AM Room 6 Right Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-5	5/14/2022 11:50:00 AM Room 8 Class Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-5	5/14/2022 11:50:00 AM Room 8 Class Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-6	5/14/2022 11:53:00 AM Room 5 Left Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-6	5/14/2022 11:53:00 AM Room 5 Left Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-7	5/14/2022 11:54:00 AM Room 5 Right Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-7	5/14/2022 11:54:00 AM Room 5 Right Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-8	5/14/2022 11:56:00 AM Room 4 Left Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0522-1423-8	5/14/2022 11:56:00 AM Room 4 Left Sink	5/20/2022 8:25:00 AM	Copper	< 0.0500 mg/l	1.3 mg/L	Std Method 3111B
0522-1423-9	5/14/2022 11:57:00 AM Room 4 Right Sink	6/8/2022 8:51:00 AM	Lead (1st Draw)	14.0 ug/l	15 ug/L	Std Method 3113B
0522-1423-9	5/14/2022 11:57:00 AM Room 4 Right Sink	5/20/2022 8:25:00 AM	Copper	0.171 mg/l	1.3 mg/L	Std Method 3111B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Thursday, June 9, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 3